



Acting Director: Victor Tryf

Purchasing and Materials  
Management Division  
City Hall, 18<sup>th</sup> Floor, West Tower  
100 Queen Street West  
Toronto, Ontario M5H 2N2

February 13, 2009

Via Fax – 1 Page

**ADDENDUM NO. 9**

**TENDER CALL 231-2008  
CONTRACT NO. 08FS-44WP**

**ODOUR CONTROL AND HVAC UPGRADES, M AND T BUILDINGS  
ASHBRIDGES BAY TREATMENT PLANT  
CLOSING DATE: 12:00 NOON, LOCAL TIME, FEBRUARY 17, 2009**

This addendum forms part of and shall be read in conjunction with the Tender Documents for Contract 08FS-44WP and amends the documents.

**Specifications**

- A9-1 Section 15960- Commissioning  
Delete Part 1.1 Contract Requirements in its entirety. Part 1.2 applies.
- A9-2 Section 14200 Crane  
Part 2.2 D Delete: Electrical: The installation is in a Class I Div.1 area- all electrical components to suit.  
Add: Electrical: The installation is in a Class I Div.1, Group D area- all electrical components to suit.

Should you have any questions regarding this addendum contact Joan Blake at 416-338-5573 or e-mail [jblake2@toronto.ca](mailto:jblake2@toronto.ca).

Please attach this addendum to your RFT document and be governed accordingly. Tenderers are to acknowledge receipt of all addenda in their Tender in the space provided in Schedule A – Form of Tender, Item 4 of the RFT document. All other aspects of the RFT remain the same.

**End of Addendum No. 9**

*B. Duffley for*

David Ferguson  
Manager,  
Construction Services,  
Purchasing and Materials Management